



Standard Practice for Enumeration of Viable Bacteria and Fungi in Liquid Fuels—Filtration and Culture Procedures¹

This standard is issued under the fixed designation D6974; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers a membrane filter (MF) procedure for the detection and enumeration of Heterotrophic bacteria (HPC) and fungi in liquid fuels with kinematic viscosities $\leq 24 \text{ mm}^2 \cdot \text{s}^{-1}$ at ambient temperature.

1.2 This quantitative practice is drawn largely from IP Method 385 and Test Method [D5259](#).

1.3 This test may be performed either in the field or in the laboratory.

1.4 The ability of individual microbes to form colonies on specific growth media depends on the taxonomy and physiological state of the microbes to be enumerated, the chemistry of the growth medium, and incubation conditions. Consequently, test results should not be interpreted as absolute values. Rather they should be used as part of a diagnostic or condition monitoring effort that includes other test parameters, in accordance with Guide [D6469](#).

1.5 This practice offers alternative options for delivering fuel sample microbes to the filter membrane, volumes or dilutions filtered, growth media used to cultivate fuel-borne microbes, and incubation temperatures. This flexibility is offered to facilitate diagnostic efforts. When this practice is used as part of a condition monitoring program, a single procedure should be used consistently.

1.6 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.7 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

¹ This practice is under the jurisdiction of ASTM Committee [D02](#) on Petroleum Products and Lubricants and is the direct responsibility of Subcommittee [D02.14](#) on Stability and Cleanliness of Liquid Fuels.

Current edition approved June 1, 2009. Published July 2009. Originally approved in 2003. Last previous edition approved in 2004 as D6974–04. DOI: 10.1520/D6974-09.

2. Referenced Documents

2.1 *ASTM Standards*:²

[D1129](#) Terminology Relating to Water

[D1193](#) Specification for Reagent Water

[D4175](#) Terminology Relating to Petroleum, Petroleum Products, and Lubricants

[D5259](#) Test Method for Isolation and Enumeration of Enterococci from Water by the Membrane Filter Procedure

[D6426](#) Test Method for Determining Filterability of Middle Distillate Fuel Oils

[D6469](#) Guide for Microbial Contamination in Fuels and Fuel Systems

[D7463](#) Test Method for Adenosine Triphosphate (ATP) Content of Microorganisms in Fuel, Fuel/Water Mixtures and Fuel Associated Water

[D7464](#) Practice for Manual Sampling of Liquid Fuels, Associated Materials and Fuel System Components for Microbiological Testing

[E1326](#) Guide for Evaluating Nonconventional Microbiological Tests Used for Enumerating Bacteria

[F1094](#) Test Methods for Microbiological Monitoring of Water Used for Processing Electron and Microelectronic Devices by Direct Pressure Tap Sampling Valve and by the Presterilized Plastic Bag Method

2.2 *Energy Institute Standards*:³

[IP 385](#) Viable aerobic microbial content of fuels and fuel components boiling below 90°C—Filtration and culture method

3. Terminology

3.1 *Definitions*:

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For Annual Book of ASTM Standards volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from Energy Institute, 61 New Cavendish St., London, WIG 7AR, U.K., <http://www.energyinst.org.uk>.

3.1.1 For definition of terms used in this method refer to Terminologies **D1129** and **D4175**, and Guide **D6469**.

3.1.2 *aseptic, adj*—sterile, free from viable microbiological contamination.

3.2 *Acronyms:*

3.2.1 *CFU*—colony forming unit

3.2.2 *HPC*—heterotrophic plate count

3.2.3 *MF*—membrane filter

3.2.4 *MEA*—malt extract agar

3.2.5 *TNTC*—too numerous to count

3.2.6 *TSA*—tryptone soy agar

3.3 *Symbols:*

3.3.1 *N*—number of CFU · L⁻¹

3.3.2 *CC*—number of colonies on membrane filter

3.3.3 *V*—sample volume filtered, mL

4. Summary of Practice

4.1 Any free water present in a fuel sample is removed by settling in a separatory funnel. After the water has been removed, a known volume of the remaining fuel is filtered through a membrane filter aseptically by one of three methods.

4.2 The filter membrane retains microbes present in the fuel. Filter replicate fuel samples through fresh membranes to permit replicate testing, growth on alternative nutrient media, or both.

4.3 After filtration, place each membrane on one of two types of agar growth media, incubate at a designated temperature for three days, and examine for the presence of CFU.

4.4 Incubate the filter media on agar for two more days, then reexamine.

4.5 Count the colonies manually or by electronic counter.

4.5.1 If practical, identify colonies on each agar medium, based on colony color, morphology, and microscopic examination.

4.5.2 Convert bacterial and fungal colony counts to CFU per litre of fuel.

5. Significance and Use

5.1 Biodeteriogenic microbes infecting fuel systems typically are most abundant within slime accumulations on system surfaces or at the fuel-water interface (Guide **D6469**). However, it is often impractical to obtain samples from these locations within fuel systems. Although the numbers of viable bacteria and fungi recovered from fuel-phase samples are likely to be several orders of magnitude smaller than those found in water-phase samples, fuel-phase organisms are often the most readily available indicators of fuel and fuel system microbial contamination.

5.2 *Growth Medium Selectivity*—Guide **E1326** discusses the limitations of growth medium selection. Any medium selected will favor colony formation by some species and suppress colony formation by others. As noted in **6.3**, physical, chemical and physiological variables can affect viable cell enumeration test results. Test Method **D7463** provides a non-culture means of quantifying microbial biomass in fuels and fuel associated water.

5.3 Since a wide range of sample sizes, or dilutions thereof, can be analyzed by the membrane filter technique (Test Methods **D5259** and **F1094**), the test sensitivity can be adjusted for the population density expected in the sample.

5.4 Enumeration data should be used as part of diagnostic efforts or routine condition monitoring programs. Enumeration data should not be used as fuel quality criteria.

6. Interferences

6.1 High non-biological particulate loads (sediment) can clog the membrane and prevent filtration.

6.2 Each CFU is assumed to originate from a single microbial cell. In reality, microbes often form aggregates which appear as a single colony. Consequently, viable count data are likely to underestimate the total number of viable organisms in the original sample.

6.3 The metabolic state of individual microbes may be affected by numerous physical-chemical variables in the fuel. Injured cells or cells that have relatively long generation times may not form colonies within the time allotted for test observations. This results in an underestimation of the numbers of viable microbes in the original fuel sample.

7. Apparatus

7.1 *Separatory Funnels*, glass, nominal capacity 500 mL.

7.2 *Measuring Cylinders*, glass, nominal capacity 100 mL and 1 L.

7.3 *Pipettes*, glass or sterile disposable plastic, nominal capacity 10 mL, or adjustable volume pipette and sterile disposable plastic tips.

7.4 *Membrane Filter*, mixed esters of cellulose, presterilized, preferably gridded, 47 mm diameter, nominal pore size 0.45 μm.

NOTE 1—While the recommended filter material is mixed esters of cellulose, the selection of membrane material will depend on individual preference and fuel type.

7.5 *Filtration Unit*, one of:

7.5.1 *Unit*, as described in Test Method **D6426**, with presterilized in-line filter housing, or

7.5.2 *Hypodermic Syringe*, sterile, 100 mL, with presterilized in-line filter housing, or

7.5.3 *Filter Holder Assembly*, single or manifold, glass, stainless steel, or polypropylene, pre-sterilized.

NOTE 2—If the vacuum filtration option (7.5.3) is chosen, a vacuum source, not more than -66 kPa will also be needed.

7.6 *Forceps*, blunt tipped.

7.7 *Filter Flask*, of sufficient capacity to receive the entire sample being filtered plus washings.

7.8 *Petri Dishes*, disposable plastic or glass, nominal diameter ≥50 mm.

NOTE 3—Pre-poured Petri dishes, containing the growth media described below are available commercially and may be substituted for the dishes listed here.

7.9 *Incubator*, capable of maintaining a temperature of 25 ± 2°C or any other temperature (within the range—ambient to 60°C), as appropriate.

7.10 *Water Bath*, capable of maintaining a temperature of $47 \pm 2^\circ\text{C}$ and receiving 500 mL bottles. Water bath capacity should be sufficient to accommodate at least one bottle of each type of agar growth medium used.

7.11 *Glass Bottles*, screw cap with gas-tight closures, 500 mL nominal capacity.

7.12 *Culture Tubes*, glass, 16 by 125 mm, screw cap.

7.13 *Autoclave*, with capacity to hold 500 mL glass bottles upright.

NOTE 4—Items 7.10-7.13 are not needed if using commercially prepared Petri dishes, as indicated in Note 3.

8. Reagents and Materials

8.1 *Purity of Reagents*—Reagent grade chemicals shall be used in all tests. Unless otherwise indicated, it is intended that all reagents conform to the specifications of the Committee on Analytical Reagents of the American Chemical Society where such specifications are available.⁴

8.2 The agar used in preparation of culture media shall be of microbiological grade. Whenever possible, use commercial culture media.

8.3 *Water Purity*—Unless otherwise indicated, references to water shall be understood to mean reagent water as defined by Type III of Specification D1193.

8.4 *Chlortetracycline*, 0.1 % (w/v) aqueous. Dissolve 0.1 g chlortetracycline in water and dilute to 100 mL. Sterilize by passing through a 0.2 μm filter.

8.5 *Detergent Solution 0.1 % (v/v)*—Dissolve 10 mL of polyoxyethylene (20) sorbitan monooleate⁵ in 990 mL water. Sterilize, either by passing through a 0.2 μm membrane filter into a sterile vessel, or autoclaving at 121°C for 15 min.

8.6 *Hydrochloric Acid*, 1 mol $\text{HCl} \cdot \text{L}^{-1}$.

8.7 *Lactic Acid*, 10 % (w/v) aqueous. Dissolve 10 g of lactic acid in water and dilute to 100 mL. Sterilize by passing through a 0.2 μm filter.

8.8 *Malt Extract Agar (MEA)*:

8.8.1 *Composition/Litre*:

Malt Extract	30 g
Mycological Peptone	5 g
Agar	15 g
Water	1 L

8.8.2 *Preparation*—Suspend the malt extract, mycological peptone and agar in 1 L of water and boil to dissolve. Adjust the pH to 5.4 ± 0.2 using either 1 mL $\cdot \text{L}^{-1}$ hydrochloric acid (8.6) or sodium hydroxide 10 % w/v (8.10). Dispense 250 mL portions into 500 mL glass screw-cap bottles (7.11). Sterilize by autoclaving at $121 \pm 2^\circ\text{C}$ for 10 min. Cool and maintain the sterilized agar in a water bath (7.10) at $47 \pm 2^\circ\text{C}$. Optionally,

after the agar has cooled to $47 \pm 2^\circ\text{C}$, add 1 mL of a 1.0 % aqueous solution of chlorotetracycline (filter sterilized by passing through a 0.2 μm filter, see 8.4) per 100 mL MEA and mix by shaking. If the medium is required at pH 3.5, add 10 % lactic acid (filter sterilized by passing through a 0.2 μm filter, see 8.7) to adjust pH. Once acidified, the MEA shall not be reheated. Make agar plates of the medium by pouring sufficient MEA into sterile petri dishes to give a layer approximately 4 mm thick. Allow to cool and set.

NOTE 5—MEA is available from various manufacturers in dehydrated form and in pre-poured plates with and without added antibiotic, either of which may be used. When sterilizing MEA prepared from commercial dehydrated media, follow the manufacturer's instructions for sterilization. Avoid overheating.

NOTE 6—Alternative media to MEA may be used, providing the ability of any alternative medium to support comparable growth of yeast and molds that are likely to be encountered in test samples can be demonstrated.

NOTE 7—Alternative antibiotics may be used providing their ability to inhibit growth of bacteria but not yeast and molds has been validated.

8.9 *Ringer's Solution, One-Quarter Strength*:

8.9.1 *Composition/Litre*:

Sodium chloride	2.25 g
Potassium chloride	0.105 g
Calcium chloride	0.12 g
Sodium bicarbonate	0.05 g
Water	1 L

8.9.2 *Preparation*—Dissolve salts in 1 L of water and dispense 10 mL portions into screw capped culture tubes (7.12). Sterilize by autoclaving at 121°C for 15 min.

NOTE 8—One-quarter strength Ringer's salts are available in tablet form from various manufacturers.

8.10 *Sodium Hydroxide*, 10 % (w/v) aqueous. Dissolve 10 g NaOH in water and dilute to 100 mL.

8.11 *Tryptone Soy Agar (TSA)*:

8.11.1 *Composition/Litre*:

Tryptone	15 g
Soy protein	5 g
Sodium chloride	5 g
Agar	15 g
Water	1 L

8.11.2 *Preparation*—Suspend the dry ingredients in 1 L of water and boil to dissolve. Dispense 250 mL portions into 500 mL glass screw-cap bottles (7.11). Sterilize by autoclaving at $121 \pm 2^\circ\text{C}$ for 10 min. Cool and maintain the sterilized agar in a water bath (7.10) at $47 \pm 2^\circ\text{C}$. Draw a sample and test the pH. If the $\text{pH} \neq 7.3 \pm 0.3$, reject the batch and make a fresh mixture. Make agar plates of the medium by pouring sufficient TSA into sterile petri dishes to give a layer approximately 4 mm thick. Allow to cool and set.

NOTE 9—TSA is available from various manufacturers in dehydrated form and in pre-poured plates.

NOTE 10—Alternative media to TSA may be used, providing the ability of any alternative medium to support comparable growth of bacteria that are likely to be encountered in test samples can be demonstrated.

9. Procedure

9.1 *Sampling*:

9.1.1 Samples shall be drawn in accordance with Practice D7464.

⁴ *Reagent Chemicals, American Chemical Society Specifications*, American Chemical Society, Washington, DC. For Suggestions on the testing of reagents not listed by the American Chemical Society, see *Annual Standards for Laboratory Chemicals*, BDH Ltd., Poole, Dorset, U.K., and the *United States Pharmacopeia and National Formulary*, U.S. Pharmacopeial Convention, Inc. (USPC), Rockville, MD.

⁵ The sole source of supply of Tween 80 known to the committee at this time is Sigma Aldrich Co., St. Louis, MO 63178, <http://www.sigmaaldrich.com>. If you are aware of alternative suppliers, please provide this information to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee,¹ which you may attend.

9.1.1.1 To reduce the risk of accidental contamination, samples intended for viable microbial enumeration shall not be used for other tests until after they are no longer needed for enumeration testing.

9.1.1.2 It may not be possible to use aseptic technique under field conditions. To reduce risk of cross-contaminating samples, sampling devices shall be rinsed with 70 % alcohol (ethanol, methanol, or isopropanol) to disinfect sample contact surfaces before samples are drawn. All samples and devices should be handled in such manner as to minimize the likelihood of introducing microbial contaminants into the sample.

9.1.1.3 Microbial contaminant populations are dynamic. Microbes within the sample may proliferate or die during the interval between collection and testing. Consequently, samples shall be processed (9.2) within 24 h after collection.

9.1.1.4 If samples are to be processed later than 4 h after collection, store the samples either on ice, or refrigerated at >0 to 5°C until processed (9.1.1.3). Avoid freezing samples. Chilled samples may be processed (9.2) without warming them to room temperature.

9.2 Sample Preparation:

9.2.1 Allow sample to stand for 1 h and then examine visually.

9.2.2 If the sample contains free water, transfer it to a sterile separatory funnel (7.1); allow the fluid and sediment to settle. After they have settled out of the fuel-phase, draw off the water and associated particulate matter into a sterile flask. Alternatively, separate the water-phase and associated particulate matter by pipetting them from the bottom of the sample bottle. (**Warning**—Fuels are toxic substances and micro-organisms may be pathogenic, allergenic, toxigenic, or some combination thereof. The analyst shall know and observe the normal good laboratory practices and safety procedures required in a microbiology laboratory while preparing, using, and disposing of cultures, reagents, and materials, and while operating sterilization and other equipment and instrumentation.)

NOTE 11—Further analysis by microscopy and other microbiological techniques, as described in Guide D6469, can be conducted on the water-phase and associated particulates.

9.2.3 Shake the fuel-phase of the sample to distribute suspended microorganisms uniformly.

9.2.4 Sub-sample test portions of the fuel-phase either using a sterile measuring cylinder (7.2) for larger volumes or sterile pipette (7.3) for smaller volumes.

NOTE 12—To increase the likelihood of recovering 20 to 60 CFU on the membrane filter, filter different volume portions: 200 mL fuel, 20 mL fuel, and 2 mL fuel. Care should be taken when adding the 2 mL aliquot to ensure even sample distribution over the membrane. Testing replicate subsamples will provide a basis for estimating the combined effect of the fuel sample's bioburden heterogeneity and procedural variability on the test results. (**Caution**—Do not pipette by mouth.)

9.3 Sample Filtration:

9.3.1 For Options A, B, or C, filter two test portions of equal volume, each through an unused filter (7.4), thereby providing one filter each for bacterial and fungal enumerations.

9.3.2 *Option A*—Using Test Method D6426 testing device (7.5.1).

9.3.2.1 Assemble the rig using sterile tubing and a pre-assembled, sterile filter housing that contains a 0.45 µm filter (7.4).

9.3.2.2 Dispense the desired sample into a sterile reservoir flask.

9.3.2.3 Allow the Test Method D6426 testing device to pump sample through the filter housing. Record the total volume of sample filtered.

9.3.2.4 *Filter Detergent Wash*—Wash the membrane free of fuel by pumping 10 mL of sterile detergent solution (8.5) through the testing device.

9.3.2.5 *Filter Rinse*—Wash the membrane free of detergent solution by filtering three successive 10 mL portions of one-quarter strength Ringer's solution (8.2).

9.3.3 *Option B*—Using a hypodermic syringe (7.5.2).

9.3.3.1 Draw desired sample portion into syringe.

9.3.3.2 Affix preassembled in-line filter housing that contains a 0.45 µm filter (7.4) to the syringe's Luer-lok fitting.

9.3.3.3 Apply gentle pressure to the syringe plunger and dispense fuel into a graduated receiving vessel (7.2 or 7.7). Record the volume of fuel filtered.

9.3.3.4 *Filter Detergent Rinse*—Remove the filter housing from the syringe carefully, taking precautions not to spill any of the fuel that remains on the inlet side of the housing. Draw 10 mL of detergent solution into the syringe, reattach the filter housing, and wash the membrane free of fuel by pumping 10 mL of sterile detergent solution (8.3) through the in-line filter housing.

9.3.3.5 *Filter Wash*—Again remove the filter housing from the syringe carefully, and draw 30 mL of one-quarter strength Ringer's solution into the syringe. Reattach the filter housing, and wash the membrane free of detergent solution by pumping 30 mL of sterile one-quarter strength Ringer's solution (8.2) through the in-line filter housing.

9.3.4 *Option C*—Vacuum filtration (7.5.3).

9.3.4.1 Using sterile forceps (7.6), place a sterile 0.45 µm pore-size filter membrane (7.4) onto the filter support, and assemble the filter holder.

9.3.4.2 Dispense the desired sample into the filter reservoir. Apply suction, and filter the test portion through the membrane filter. Record the volume of sample filtered.

9.3.4.3 *Filter Detergent Rinse*—Maintaining suction, wash the membrane filter free of fuel with a 10 mL portion of sterile detergent solution (8.3).

9.3.4.4 *Filter Rinse*—Maintaining suction, wash the filter free of detergent solution with three successive 10 mL portions of sterile one-quarter strength Ringer's solution (8.2).

9.4 Transfer to Growth Media:

9.4.1 Remove the membrane filter from filter housing. (**Warning**—Fuel samples are flammable. Disinfect forceps and glassware by rinsing in ethanol, methanol, or isopropanol and allowing the alcohol to evaporate. Open flames must not be used in the vicinity of fuel samples.)

9.4.1.1 Carefully disassemble the filter housing, keeping the exposed surface of the filter membrane facing up.

9.4.1.2 Using a sterile forceps, remove the filter.

9.4.2 Using a rolling action, apply the membrane filter, grid-side up, onto the surface of the appropriate medium MEA (8.4) or TSA (8.5) media in the petri dishes. Ensure good contact between the membrane filter and the medium.

9.4.3 Use a fine point permanent marker to label the bottom of each petri dish with the sample and growth medium identity.

9.5 Incubation,

9.5.1 Place the dishes in an incubator (7.13) controlled at $25 \pm 2^\circ\text{C}$. Invert the petri dishes containing TSA.

9.5.1.1 If the temperature of the system from which the sample was collected is $>5^\circ\text{C}$ warmer than the standard incubation temperature, using an incubator adjusted to the ambient temperature may improve viable cell recovery. Although 25°C is suitable for most systems, a higher incubation temperature, at or within 5°C of the temperature of the system from which the sample was collected, may be used when the temperature of the system sampled exceeds 30°C . Incubation temperature shall be controlled at $\pm 2^\circ\text{C}$.

9.5.2 Examine TSA and MEA dishes for the appearance of colonies after three days and MEA again after five days incubation.

9.6 Colony Counting:

9.6.1 Using a counting device, determine the number of CFU that have developed on the membrane surface after three days (TSA) and five days incubation (MEA).

9.6.2 Calculate the CFU bacteria per litre in the sample from the colony count on the TSA plate and the CFU fungi per litre from the colony count on the MEA plate (see 9.6.1) using the following equation:

$$N = \frac{CC \times 1000}{V} \quad (1)$$

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).

where:

N = number of CFU $\cdot \text{L}^{-1}$,

CC = colony count on the plate, see 9.6, and

V = sample volume filtered, in millilitres.

9.6.3 If multiple portions were filtered, average and compute the standard deviation for the results of the replicate CFU $\cdot \text{L}^{-1}$ calculations.

9.6.4 If no colonies appeared on the growth media let $CC = 1$, compute N and report results as $<N$ CFU bacteria $\cdot \text{L}^{-1}$ or as $<N$ CFU fungi $\cdot \text{L}^{-1}$, as appropriate.

10. Report

10.1 Report the results as CFU bacteria $\cdot \text{L}^{-1}$ and as CFU fungi $\cdot \text{L}^{-1}$, as appropriate. If no colonies appeared on the growth media let $CC = 1$, compute N and report results as $<N$ CFU bacteria $\cdot \text{L}^{-1}$ or as $<N$ CFU fungi $\cdot \text{L}^{-1}$, as appropriate.

10.2 Report the incubation temperature.

11. Precision and Bias

11.1 *Precision*—The precision of the procedure in Practice D6974 cannot be determined due to the inherent taxonomic and physiological variability of fuel microbial contaminants.

11.2 *Bias*—Since there is no accepted reference material suitable for the bias in this test method, no statement on bias is made.

12. Keywords

12.1 bacteria; biodegradation; biodeterioration; colony forming unit; enumeration; fuel microbiology; fungi; membrane filter technique; viable count